

FIG 1: MATERIAL CLASSIFICATION.

	Flame Spread Index	Smoke Developed Index
Class A	0-25	0-450
Class B	26-75	0-450
Class C	76-200	0-450